## BARLOWS

## Non Domestic Gas Safety Record



This inspection is for gas safety purposes only in accordance with Gas Safety (Installation and Use) Regulations. Flues were inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the Flue integrity, construction and lining has not been carried out.

Form Serial Number: FRM/U0001642

Job Address:

Name: Tarporley Community Centre Contact:

Address: High Street, Tarporley

Cheshire,

PostCode: CW6 0AY Telephone: +447808513714

URN: Tony Yeates

Registered Business Details: GAS SAFE NO: 203366

Gas Operative : Hadrian Harmer
Name : Barlows UK Ltd

Address: Marjorie House,, Chadderton,

Oldham,, Greater Manchester,

PostCode: OL9 9LQ Telephone: 0161 628 9111

Client Landlord's Details:

Name: Tarporley Community Centre

Address: High Street, Tarporley

Cheshire,

PostCode: CW6 0AY Telephone: 01829 730136

Rented Accommodation: No No of appliance tested: 3

Visual check to ensure burner pressure + flue gas test points have been replaced? Yes

Appliance Details							Inspection Details												
Location		Туре	Make	Model	Landlords Appliance	Appliance Inspected	Flue Type	Operating Pressure	Device Correct Operation	Ventilation Provision Satisfactory	Visual Condition of Flue	Termination Satisfactory	Flue Performance Check	CO PPM	CO2%	CO/ CO2 Ratio	Spillage Test	Appliance Serviced	Safe To Use
1	Plant room	Heat only	Potterton	EC two 90	Yes	Yes	RS	19.1 Mbars	Yes	Yes	Pass	Pass	Pass	43	0.0004	9.2	N/A	Yes	Yes
2	Plant room	Combi	Worcester	Greenstar 25i erp	Yes	Yes	RS	20.4 Mbars	Yes	Yes	Pass	Pass	Pass	19	0.0002	9.3	N/A	Yes	Yes
3	Cleaning cupboard	Combi	Worcester	28i junior	Yes	Yes	RS	19.7 Mbars	Yes	Yes	Pass	Pass	Pass	80	0.0008	9.4	N/A	Yes	Yes

Ken Wood

				Derect De									
Appliance #	nce # Defect Identified			Remedial Action			Warning Issued	V	Warning Note Serial No				
Smoke/ CO Alarm Details													
1.	scation	Type	Approved Alarm Fitted	Alarm Evniry	Tocting	of Alarm Caticfactory	Pattory/ Hard wire	od	Roplacoment Required				

	Smoke/ CO Alarm Details										
Location		Туре	Approved Alarm Fitted	Alarm Expiry	Testing of Alarm Satisfactory	Battery/ Hard wired	Replacement Required				
1 Cleaners cupboard		СО	Yes	N/A	Yes	Battery	No				
2 Plant room		СО	Yes	N/A	Yes	Battery	No				

Gas installation pipework satisfactory visual inspection Yes

Emergency control accessible Yes

Satisfactory gas tightness test Yes

Equipotential bonding satisfactory Yes

Minimum O2 N/A Minimum CO N/A Minimum CO2 N/A

This safety record is issued by: Signed

AM

Printed name Hadrian Harmer

Received by:

Not Present

Date:

e: 08-Aug-2023