



# Non Domestic Gas Safety Record



This inspection is for gas safety purposes only in accordance with Gas Safety (Installation and Use) Regulations. Flues were inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the Flue integrity, construction and lining has not been carried out.

**Form Serial Number: FRM/P0004678**

**Registered Business Details:** GAS SAFE NO: **L9e-**

Gas Operative : Craig Swinden  
 Name : Barlows UK Ltd Plumbing and Heating  
 Address : Marjorie House, Watts Street  
 Chadderton, Oldham  
 PostCode : OL9 9LQ Telephone : 0161 6289111

**Job Address:**

Name : Tarporley Community Centre Contact : Tony Yeates  
 Address : High Street, Tarporley  
 Cheshire,  
 PostCode : CW6 0AY Telephone : 07708 098730  
 URN : TONY

**Client Landlord's Details:**

Name : Tarporley Community Centre  
 Address : High Street, Tarporley  
 Cheshire,  
 PostCode : CW6 0AY Telephone : 01829 730136  
 Rented Accommodation : Yes No of appliance tested : 4

**Appliance Details**

Appliance Details										Inspection Details									
Location	Type	Make	Model	Landlords Appliance	Appliance Inspected	Flue Type	Operating Pressure	Device Correct Operation	Ventilation Provision Satisfactory	Visual Condition of Flue	Termination Satisfactory	Flue Performance Check	CO PPM	CO2%	CO/CO2 Ratio	Spillage Test	Appliance Serviced	Safe To Use	
1	Disabled toilets	Gas boiler	Worcester	28i junior	Yes	Yes	RS	26 kW/h	Yes	N/A	Pass	Pass	N/A	105	9.5	0.0011	N/A	Yes	Yes
2	Main plant room	Gas boiler	Worcester	24i system boiler	Yes	Yes	RS	24 kW/h	Yes	N/A	Pass	Pass	N/A	89	9.6	0.0009	N/A	Yes	Yes
3	Main plant room	Gas water heater	Andrews	25/49	Yes	Yes	OF	10 Mbars	Yes	Yes	Pass	Pass	Pass	74	8.8	0.0008	Pass	Yes	Yes
4	Main plant room	Gas boiler	Potterton	Ec two 90	Yes	Yes	OF	81 kW/h	Yes	Yes	Pass	Pass	Pass	34	9.3	0.0003	Pass	Yes	Yes

**Defect Details**

	Defect Identified	Remedial Action	Warning Label Fitted	Warning Issued	Warning Note Serial No
1					
2					
3					

**Smoke/ CO Alarm Details**

	Location	Type	Approved Alarm Fitted	Alarm In Date	Testing of Alarm Satisfactory	Battery/ Hard wired	Replacement Required
1							
2							

Gas installation pipework satisfactory visual inspection	Yes
Emergency control accessible	Yes
Satisfactory gas tightness test	Yes
Equipotential bonding satisfactory	Yes

This safety record is issued by: Signed  Printed name Craig Swinden

Received by: Tony yeates 

Date: 02-Oct-2017